

Materials Specification – 24 for WATER SERVICE LINE PIPE – 2-INCH AND SMALLER

1. GENERAL

Water service line pipe shall be manufactured in accordance ASTM B 88 with the following additional requirements or exceptions.

2. SIZE OF PIPE

This Specification covers water service line pipe in 3/4, 1, 1 1/4, 1 1/2, and 2-inch nominal diameters.

3. PIPE MATERIAL

Water service line pipe shall be seamless copper water tube in accordance with ASTM B 88, furnished in coils, annealed, Type K Copper UNS No. 12200.

4. CERTIFICATION

The manufacturer shall furnish a sworn statement that the inspection and all specified tests have been completed and that results comply with the requirements of these Standards. A copy of the Certification, including compliance with NSF/ANSI 61, shall be provided to Denver Water.

5. PLACE OF MANUFACTURE

Water service line pipe installed in City and County of Denver and Total Service contract areas shall be manufactured domestically.

6. ACCEPTABLE MANUFACTURERS

Cambridge-Lee Industries
Cerro Flow Products
CMC Howell Metal
Mueller Industries
Wieland Copper

*Material Specification – 24
Water Service Line Pipe – 2-Inch and Smaller*