



**NOTES:**

1. NUT MATERIAL SHALL BE CAST IRON IN ACCORDANCE WITH ASTM A 126 CLASS B OR DUCTILE IRON IN ACCORDANCE WITH ASTM A 536.
2. HOLE THROUGH NUT TO MATCH VALVE ACTUATOR SHAFT OR VALVE STEM EXTENSION. HOLE SHOWN FITS VALVE OPERATOR EXTENSION ON SHEET 22.
3. NUT SHALL BE COATED WITH FUSION-BONDED EPOXY, OR LIQUID EPOXY, MINIMUM 16 MIL DFT IN ACCORDANCE WITH AWWA C210, FEDERAL COLOR NO 2577U.
4. AN ARROW AND THE WORD OPEN SHALL BE CAST ON THE FLANGE BASE TO INDICATE DIRECTION OF OPENING IN ACCORDANCE WITH AWWA C509.

<b>DENVER WATER</b> <small>1600 West 12th Avenue • Denver, Colorado 80204          Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
<b>RECYCLED WATER SYSTEM          PENTAGON OPERATING NUT</b>	
Scale: <u>  NONE  </u>	Date: <u>  June 2014  </u>
Drawn: <u>  BGS  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  [Signature]  </u>	Dr. <u>  127  </u> No. <u>  35  </u>