



NOTES:

1. SEE MS-28 FOR APPROVED PRECAST CONCRETE VAULTS.
2. ACCESS STAIRS WITH A DOOR OUTSIDE OF THE PAVEMENT MAY BE REQUIRED ON STREETS WITH HEAVY TRAFFIC.
3. SEE SHEET 43 FOR A CROSS SECTION.
4. DO NOT PLACE SUMP DIRECTLY UNDER A VAULT ACCESS OPENING.
5. THIS VAULT IS SUITABLE FOR CHECK VALVE INSTALLATIONS.
6. WHEN INSTALLING AN 8" OR SMALLER PRESSURE REGULATING VALVE ON A 20" OR SMALLER MAIN, PIPING SHALL BE THE SAME SIZE AS THE PRESSURE REGULATING VALVE AND ONE PIPE SIZE SMALLER THAN THE MAIN. (LARGER SIZE CONDUIT AND PRESSURE REGULATING VALVES REQUIRE APPROVAL OF LINE SIZE).
7. FOR PIPE SIZES LESS THAN 12", CORP STOPS SHALL BE 1". FOR PIPE SIZES 12" AND LARGER, CORP STOPS SHALL BE 2".

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
PRESSURE REGULATING OR CHECK VALVE RECTANGULAR VAULT TYPICAL PLAN	
Scale: <u> NONE </u>	Date: <u> June 2014 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>