

1. SERVICE LINES WILL NOT BE ACTIVATED UNLESS THE TAP, METER SETTING, AND SERVICE LINE ARE IN COMPLIANCE WITH THE MOST CURRENT VERSION OF THE ENGINEERING STANDARDS, APPROVED PROJECT DRAWINGS, AND METER INSPECTION WRITTEN INSTRUCTIONS, AS APPLICABLE. DEVIATIONS FROM THESE PLANS AND STANDARDS MUST BE APPROVED IN ADVANCE IN WRITING BY DENVER WATER.
2. AN ON-SITE PRECONSTRUCTION MEETING WITH A METER INSPECTOR IS REQUIRED FOR TAPS AND SERVICE LINES LARGER THAN 1" AND FOR PROJECTS INVOLVING MORE THAN ONE TAP AND SERVICE. PRECONSTRUCTION MEETINGS MAY BE SCHEDULED BY CALLING THE METER INSPECTION SUPERVISOR AT 303-628-6145.
3. THE METER AND AMR DEVICE LOCATION SHALL BE APPROVED BY DENVER WATER METER INSPECTION. METER SETTINGS LARGER THAN 1" SHALL BE APPROVED IN THE FIELD BY A METER INSPECTOR PRIOR TO THE INSTALLATION OF ANY SERVICE LINE OR TAP. CALL 303-628-6145 TO MAKE AN APPOINTMENT FOR AN ON-SITE APPROVAL MEETING.
4. METER SETTINGS, SERVICE LINES, AND APPURTENANCES LARGER THAN 1" MUST BE INSPECTED BY A DENVER WATER METER INSPECTOR BEFORE BEING BACKFILLED.
5. METER PITS AND VAULTS MUST BE SET FLUSH WITH THE FINAL GRADE OF THE LANDSCAPE, WHICH MUST INCLUDE PROPER DEPTH OF SOIL AMENDMENT. IF THE STREET OR GROUND IS NOT TO FINAL GRADE AT THE TIME OF THE METER INSTALLATION OR INSPECTION, THE OWNER MUST RAISE OR LOWER THE METER PIT/VAULT WHEN FINAL GRADE IS ESTABLISHED. THE METER SETTING MUST BE ADJUSTED TO STANDARDS AFTER PIT/VAULT GRADE IS ADJUSTED.
6. PROTECT THE CURB BOXES, METER PITS, AND VAULTS AND AUTOMATIC METER READING DEVICES THROUGHOUT CONSTRUCTION. NO METER MAY BE REMOVED FROM ITS INSTALLED LOCATION UNTIL THE EXISTING TAP HAS BEEN CUT AT THE MAIN.
7. A BYPASS IS REQUIRED ON METERS 1 1/2" AND LARGER. BYPASSES ARE NOT PERMITTED ON IRRIGATION SERVICES.
8. BACKFLOW PREVENTION DEVICES MAY BE REQUIRED IN CONFORMANCE WITH THE ENGINEERING STANDARDS AND STANDARD DETAILS. IF REQUIRED, THEY MUST BE IN PLACE BEFORE THE FINAL METER INSPECTION.
9. MASTER METER AND READ AND BILL DISTRIBUTORS MAY IMPOSE ADDITIONAL STANDARDS NOT REQUIRED BY DENVER WATER.
10. METER PITS SHALL BE FURNISHED WITH PLASTIC FROST LID WITH A 3" DEEP PAN, FIVE DRAIN HOLES, LIFTING HANDLE, AND SLOT FOR ERT WIRE RUNNING FULL DEPTH OF LIP.
11. IN MOST CASES THE AMR DEVICE WILL MOUNT THROUGH THE CAST IRON LID, OR UNDER THE COMPOSITE LID. IN SOME CASES THE REMOTE AMR DEVICE WILL BE REQUIRED PER SHEET 66. METERS SHALL BE FURNISHED WITH ELECTRONIC DIGITAL ENCODER REGISTERS OR MECHANICALLY ENCODED REGISTERS WITH A REMOTE AMR DEVICE FOR EACH REGISTER.
12. REMOTE AMR DEVICE WILL BE INSTALLED AT A LOCATION DETERMINED BY DENVER WATER AT THE TIME OF METER INSPECTION. IN MOST CASES, AMR DEVICE WILL BE INSTALLED ON THE OUTSIDE OF THE BUILDING FACING A PUBLIC STREET. OWNER MUST PROVIDE CONDUIT AND SIGNAL WIRE FROM METER TO AMR DEVICE LOCATION. (SEE SHEET 66 FOR DETAIL OF CONDUIT AND OUTSIDE AMR DEVICE MOUNTING).

ERRATA 5

	
DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
<h3>GENERAL METER & SERVICE NOTES</h3>	
Scale: <u> NONE </u> _ _ _	Date: <u> November </u> <u> 2014 </u>
Drawn: <u> C.B.B. </u> _ _ _	Ck: <u> K ROSS </u> _ _ _
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u> _