



ERRATA 5

NOTES:

1. PLACE CURB STOP AND STOP BOX IN PUBLIC RIGHT-OF-WAY BEHIND CURB AS SHOWN.
2. INSIDE METER SHALL BE PLACED IN BASEMENT WITH A FLOOR DRAIN WITHIN 10'-0" OF THE METER. THE METER SHALL BE PROTECTED FROM FREEZING.
3. NO BENDS, FITTINGS, CONNECTIONS, OR CHANGES IN PIPE SIZE ARE PERMITTED ON THE SERVICE LINE FROM THE CORPORATION STOP TO THE METER OUTLET VALVES EXCEPT AS SHOWN.
4. NEW INSIDE METER INSTALLATIONS ARE NOT ALLOWED. EXISTING INDOOR METERS MUST MEET THESE REQUIREMENTS.

DENVER WATER

1600 West 12th Avenue • Denver, Colorado 80204
 Phone (303) 628-6000 • Telecopier No. (303) 628-6851

SERVICE LINE, BOX AND INSIDE METER INSTALLATION FOR EXISTING 3/4' & 1" METERS

Scale: NONE Date: November 2014

Drawn: C.A.M. Ck: K ROSS

Approved: Steph C. Pennington Dr. 127 No. 35