



ISOMETRIC VIEW



ELEVATION



PLAN

NOTES:

1. THE METER SHALL BE PROTECTED FROM FREEZING & DAMAGE.
2. NO BENDS, FITTINGS, CONNECTIONS, OR CHANGES IN PIPE SIZE ARE PERMITTED ON THE SERVICE LINE FROM THE CORPORATION STOP TO THE METER OUTLET VALVES EXCEPT AS SHOWN.
3. IF THE METER IS BOXED IN OR PLACED BEHIND A WALL, PROVIDE AN ACCESS OPENING 36" WIDE FROM ABOVE THE OUTLET VALVE TO THE FLOOR.
4. VALVES MUST BE ACCESSIBLE FROM THE OPENING.
5. METER TO BE CENTERED IN THE OPENING.

DENVER WATER 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851	
INSIDE SETTING FOR EXISTING 3/4" & 1" METER WITH AMR	
Scale: <u> NONE </u>	Date: <u> March 2012 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>