


**ELEVATION**



**MANUAL DRAIN VALVE**

**NOTES:**

1. CONCRETE PAD PENETRATIONS SHALL BE 1" LARGER THAN PIPE DIAMETER.
2. DIAMETER OF FITTINGS, NIPPLE, AND TUBING SHALL BE EQUAL IN DIAMETER TO THE BACKFLOW PREVENTER.
3. REFER TO LOCAL CODES AND MANUFACTURER REQUIREMENTS FOR SPECIFIC INSTALLATION INSTRUCTIONS.

<b>DENVER WATER</b> <small>1600 West 12th Avenue • Denver, Colorado 80204          Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
<b>IRRIGATION OUTSIDE SETTING FOR 2" &amp; SMALLER REDUCED PRESSURE PRINCIPLE ASSEMBLY IN ENCLOSURE</b>	
Scale: <u>  NONE  </u>	Date: <u>  June 2014  </u>
Drawn: <u>  C.A.M.  </u>	Ck: <u>  K ROSS  </u>
Approved: <u>  [Signature]  </u>	Dr. <u>  127  </u> No. <u>  35  </u>