



**NOTES:**

1. VAULT PENETRATIONS SHALL BE 1" LARGER THAN PIPE OUTSIDE DIAMETER.
2. DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY SHALL BE LOCATED IN LANDSCAPED AREAS.
3. TOTAL COPPER TUBING LENGTH MEASURED FROM MAIN TO METER TO DOUBLE CHECK BACKFLOW PREVENTION ASSEMBLY TO DRINKING FOUNTAIN SHALL HAVE A MAXIMUM DEVELOPED LENGTH OF 250'.
4. REFER TO LOCAL CODES & MANUFACTURER REQUIREMENTS FOR INSTALLATION INSTRUCTIONS.

<b>DENVER WATER</b> 1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851	
<b>DRINKING FOUNTAIN DOUBLE CHECK VALVE BELOW GROUND INSTALLATION</b>	
Scale: <u>  NONE  </u>	Date: <u>February 2013</u>
Drawn: <u>  C.A.M.  </u>	Ck: <u>  K ROSS  </u>
Approved: <u><i>J.H. B...</i></u>	Dr. <u>127</u> No. <u>35</u>