



NOTES:

1. USE OF A DENVER WATER HYDRANT REQUIRES A VALID HYDRANT USE PERMIT.
2. REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTION ASSEMBLY SHALL BE APPROVED BY DENVER WATER AND FULLY SUPPORTED WHEN CONNECTED TO THE FIRE HYDRANT.
3. REDUCED PRESSURE PRINCIPLE BACKFLOW PREVENTION ASSEMBLY SHALL BE USC FCCCHR APPROVED.
4. THE BACKFLOW PREVENTION ASSEMBLY SHALL BE TESTED ANNUALLY AND A COPY OF THE TEST SHALL BE SENT TO DENVER WATER.
5. THE CONTRACTOR WILL BE HELD RESPONSIBLE FOR ANY DAMAGE TO FIRE HYDRANT DURING USE.
6. SUPPORT OF BACKFLOW PREVENTION ASSEMBLY IN LIEU OF ADJUSTABLE SUPPORTS SHALL BE APPROVED IN WRITING BY DENVER WATER.

ERRATA 7

DENVER WATER <small>1600 West 12th Avenue • Denver, Colorado 80204 Phone (303) 628-6000 • Telecopier No. (303) 628-6851</small>	
STANDARD HYDRANT PERMIT INSTALLATION	
Scale: <u> NONE </u>	Date: <u> November </u> 2016
Drawn: <u> C.B.B. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>