

DENVER BOARD OF WATER COMMISSIONERS

Meeting Date: April 10, 2013

Board Item: V-A- 9

**Tabulation of Proposals for
Chatfield Pump Station High Side
Pump Run No. 7 Addition
Contract 14041A**

Action by Consent Action Information

On March 26, 2013, proposals were received for the Chatfield Pump Station High Side Pump Run No. 7 Addition Project. The project includes demolition of discharge piping in two adjacent runs and furnishing and installing the following: various piping and fittings ranging in size from 8-inch to 18-inch, 5 MGD pump, 400hp motor, variable frequency drive, three check valves, a high performance butterfly valve, hydraulic power unit controls, and a flowmeter.

Four firms were provided with proposal packages. Four proposals were received with the low proposal submitted by Intermountain Electric, Inc. of Denver, Colorado in the amount of \$488,411.00. The Engineer's Estimate for the work was \$729,000.00. The Engineer's Estimate for the Chatfield Pump Station project included a contingency amount in anticipation of electrical systems analysis being necessary.

The Minority and Women Business Enterprise (MWBE) goal established for this construction project is 3% participation. Intermountain Electric, Inc. achieved 4.30% MWBE participation.

The 2013 Capital Improvement Plan (MPC 1BC0064) includes sufficient funds for this project. Due to the long lead time on the equipment, construction as this project will begin in 2014. Sufficient funds have been moved to 2014.

Recommendation:

It is recommended that the Board award Contract 14041A to Intermountain Electric, Inc. for the Chatfield Pump Station High Side Pump Run No. 7 Addition Project in the amount of \$488,411.00.

Approvals:

Respectfully submitted,


Robert J. Mahoney
Director of Engineering


James S. Lochhead
CEO/Manager