



FIRELINE CONNECTION WITH DOMESTIC SERVICE TEE UP TO 2"



FIRELINE CONNECTION WITH DOMESTIC SERVICE TEE 3" AND LARGER



NOTE:
COMBINATION SERVICE CANNOT BE USED WHERE THE SPACING BETWEEN SERVICES EXCEEDS THE DISTANCE FROM THE MAIN TO THE DOMESTIC TAP OR TEE.

- ① EXIST MAIN
- ② TAPPING SLV OR SWIVEL TEE
- ③ TAPPING VALVE OR MJ GV
- ④ DI DBL SPIGOT PIPE
- ⑤ MJ GV
- ⑥ RESTRAINT DEVICE
- ⑦ CONC KB
- ⑧ BRASS SERVICE SADDLE
- ⑨ POLYETHYLENE WRAPPED
- ⑩ 90° FITTING
- ⑪ MJ TEE
- ⑫ SERVICE INSULATOR
- ⑬ CORP STOP (UP TO 2")
- ⑭ CU PIPE (UP TO 2")
- ⑮ CURB STOP

DENVER WATER
1600 West 12th Avenue • Denver, Colorado 80204
Phone (303) 628-6000 • Telecopier No. (303) 628-6851

FIRELINE CONNECTION WITH DOMESTIC SERVICE TAP

Scale: <u> NONE </u>	Date: <u> June 2010 </u>
Drawn: <u> C.A.M. </u>	Ck: <u> K ROSS </u>
Approved: <u> [Signature] </u>	Dr. <u> 127 </u> No. <u> 35 </u>