PUMPING STATION CAPACITIES - 2002

Center of pump U.S.G.S. elevation in parenthese

Pump Station/Elevation	Pump Number	Make of Pump	Make of Motor	Horse-power	Head in Feet	Capacity in MGD	Method of Operation[1]
BELLEVIEW (5,714)	4	Goulds	Ideal Electric	900	260	15.0	M R
(High Pressure)	5	Worthington	Westinghouse	300	260	5.0	M R
11200W. Belleview Ave.	6	Worthington	General Electric	600	260	10.0	M R
	7	Worthington	General Electric	900	260	15.0	M R
				2,700		45.0	
BELLEVIEW (5,714)	1	Goulds	General Electric	250	175	6.0	M R
(Low Pressure)	2	Goulds	General Electric	400	175	10.0	M R
11200W. Belleview Ave.				650		16.0	
BROOMFIELD (5,316)	1	Patterson	Ideal Electric	400	350	5.0	M R
9265 Washington St.	2	Patterson	Ideal Electric	400	350	5.0	M R
	3	Patterson	Ideal Electric	400	350	5.0	M R
				1,200		15.0	
CAPITOL HILL (5,387)	3	Wheeler Economy	General Electric	800	175	20.0	M R
1000 Elizabeth St.	4	Byron Jackson	General Electric	400	175	12.0	M R
	5	Cameron	General Electric	700	164	20.0	M R
	6	Byron Jackson	Westinghouse	600	175	17.0	M R
	7	Byron Jackson	Westinghouse	800	175	23.0	M R
				3,300		92.0	
CASTLEWOOD (5785)[2]	1	Paco	Lincoln Linguard	75		2.3	M L
9502 E.Arapahoe Rd.	2	Paco	Lincoln Linguard	75		2.3	M L
				150		4.6	
CHATFIELD (5,717)	1	ITT	US Motor	200	150	5.0	M R
8371 Continental Divide Rd.	2	ITT	US Motor	200	150	5.0	M R
(Low Pressure)	3	ITT	US Motor	200	150	5.0	M R
				600		15.0	
CHATFIELD (5,717)	5	ITT	US Motor	400	320	5.0	M R
8371 Continental Divide Rd.	6	ITT	US Motor	400	320	5.0	M R
(High Pressure)				800		10.0	
CHERRY HILLS (5,380)	1	Worthington	General Electric	1,000	220	20.0	M R
1590 Radcliff Ave.	2	Worthington	General Electric	1,000	220	20.0	M R
	3	Worthington	General Electric	1,000	220	20.0	M R
	4	Worthington	General Electric	1,000	220	20.0	M R
	5	Worthington	General Electric	1,000	220	20.0	M R
	6	Worthington	General Electric	1,000	220	20.0	M R
				6,000		120.0	
CLARKSON (5,482)[2]	1	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
5300 S. Clarkson St.	2	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
	3	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
	4	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
	5	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
	6	Fairbanks Morse	Fairbanks Morse	150	234	2.1	M R
				900		12.6	
EINFELDT (5,341)	2	Wheeler Economy	General Electric	800	175	20.0	M R
1900 S. University Blvd.	3	Byron Jackson	General Electric	600	175	17.0	M R
	4	Byron Jackson	General Electric	400	175	12.0	M R
	5	Byron Jackson	Westinghouse	200	175	5.3	M R
	6	Worthington	Electric Machinery	800	175	20.0	M R
	7	Wheeler Economy	General Electric	800	175	20.0	M R
				3,600		94.3	

[1]M=Manual, R=Remote, L=Local

[2]Vault Type Structure (underground)

(Continued next page)

PUMPING STATION CAPACITIES - 2002 (Continued)

Center of pump U.S.G.S. elevation in parentheses

Pump Station/Elevation	Pump Number	Make of Pump	Make of Motor	Horse-power	Head in Feet	Capacity in MGD	Method of Operation[1]
FIFTY-SIXTH AVENUE (5,203)	2	Allis Chalmers	Ideal Electric	1,750	450	15.0	M R
7355 56th Ave.	3	Allis Chalmers	Ideal Electric	1,750	450	15.0	M R
	4	Allis Chalmers	Ideal Electric	1,750	450	15.0	M R
	5	Allis Chalmers	Ideal Electric	1,750	450	15.0	M R
	8	Gould	U.S. Motor	500	75	30.0	M R
	9	Gould	U.S. Motor	500	75	30.0	M R
				8,000		120.0	
GREEN MOUNTAIN (5,837)	1	Patterson	General Electric	700	260	10.0	M R
12400 W. Jewell Ave.	2	Patterson	General Electric	350	260	5.0	M R
	3	Patterson	General Electric	350	260	5.0	M R
	4	Patterson	General Electric	700	260	10.0	M R
				2,100		30.0	
HIGHLANDS (5,704)	1	Fairbanks Morse	General Electric	125	165	3.0	M R
(Low Pressure)	2	Fairbanks Morse	General Electric	125	165	3.0	M R
8100 S. University Blvd.	3	Fairbanks Morse	General Electric	125	165	3.0	M R
	4	Fairbanks Morse	General Electric	125	165	3.0	M R
	5	DeLaval	Ideal Electric	350	165	10.0	M R
	6	DeLaval	Ideal Electric	350	165	10.0	M R
	7	DeLaval	Ideal Electric	350	165	10.0	M R
				1,550		42.0	
HIGHLANDS (5,704)	1	Gould	General Electric	900	260	15.0	M R
(High Pressure)	4	Gould	General Electric	900	260	15.0	M R
8100 S. University Blvd.	6	Gould	General Electric	300	110	10.0	M R
	7	Gould	General Electric	300	110	10.0	M R
	8	Gould	General Electric	150	110	5.0	M R
	9	Gould	General Electric	150	110	5.0	M R
				2,700		60.0	
HILLCREST (5,602)	1	Allis Chalmers	Allis Chalmers	50	169	1.0	M R
(Low Pressure)	2	Allis Chalmers	Allis Chalmers	100	167	2.0	M R
4200 S. Happy Canyon Rd.	3	DeLaval	Electric Machinery	200	163	5.0	M R
	4	DeLaval	Electric Machinery	400	163	11.0	M R
	5	DeLaval	Electric Machinery	400	163	11.0	M R
	6	Worthington	Fairbanks Morse	400	163	11.0	M R
	7	Worthington	Fairbanks Morse	400	163	11.0	M R
				1,950		52.0	
HILLCREST (5,602)	8	American Marsh	Westinghouse	75	320	0.8	M R
(High Pressure)	10	DeLaval	Electric Machinery	350	313	4.8	M R
4200 S. Happy Canyon Rd.	11	DeLaval	Electric Machinery	800	315	10.5	M R
	12	DeLaval	Electric Machinery	800	315	10.5	M R
	13	Patterson	Ideal Electric	900	320	10.0	M R
				2,925		36.6	
KENDRICK (5,607)	1	Patterson	Ideal Electric	300	120	10.0	M R
(Low Pressure)	2	DeLaval	General Electric	300	117	10.0	M R
9380 W. Jewell Ave.	3	Worthington	General Electric	75	119	2.9	M R
	4	Worthington	General Electric	75	119	2.9	M R
	5	Worthington	General Electric	75	119	2.9	M R
				825		28.7	

[1]M=Manual, R=Remote, L=Local

(Continued next page)

PUMPING STATION CAPACITIES - 2002 (Continued)

Center of pump U.S.G.S. elevation in parentheses

Pump Station/Elevation	Pump Number	Make of Pump	Make of Motor	Horse-power	Head in Feet	Capacity in MGD	Method of Operation[1]
KENDRICK (5,607)	7	Worthington	Electric Machinery	800	260	10.0	M R
(High Pressure)	8	Worthington	Electric Machinery	800	260	10.0	M R
9380 W. Jewell Ave.	9	Goulds	Waukesha[3]	700	260	10.0	M R
	10	DeLaval	Waukesha[3]	400	260	5.0	M R
	11	Patterson	Ideal Electric	700	260	10.0	M R
				3,400		45.0	
LAKERIDGE (5,516)	1	American	United States	50	120	1.7	M R
2700 S. Raleigh St.	2	Pacific	Ideal Electric	75	120	2.9	M R
	3	Pacific	Ideal Electric	75	120	2.9	M R
	4	Allis Chalmers	Allis Chalmers	50	120	2.0	M R
				250		9.5	
LAMAR (5,443)[2]	1	Worthington	Marathon Electric	100	120	2.9	M R
6301 W. Yale Ave.	2	Worthington	Marathon Electric	100	120	2.9	M R
	3	Worthington	Fairbanks Morse	75	120	2.0	M R
				275		7.8	
LONE TREE (5,904)	3	Gould	Siemens & Allis	300	127	10.0	M R
(Low Pressure)	4	Gould	Siemens & Allis	150	127	5.0	M R
7700 E. Chapparel Rd.	5	Gould	Siemens & Allis	150	127	5.0	M R
				600		20.0	
LONE TREE (5,904)	6	Gould	Siemens & Allis	300	227	5.0	M R
(High Pressure)	7	Gould	Siemens & Allis	600	227	10.0	M R
7700 E. Chapparel Rd.	8	Gould	Siemens & Allis	600	227	10.0	M R
				1,500		25.0	
MARSTON (5,485)	1	Worthington	Waukesha[3]	700	166	20.0	M R
(Low Pressure)	2	Worthington	General Electric	700	166	20.0	M R
5700 W. Quincy Ave.	3	Worthington	General Electric	700	166	20.0	M R
	4	Worthington	General Electric	700	166	20.0	M R
	5	Worthington	General Electric	700	166	20.0	M R
				3,500		100.0	
MARSTON (5,485)							
(High Pressure)							
5700 W. Quincy Ave.	8	Patterson	Waukesha[3]	400	260	6.5	M R
	9	Ingersoll-Rand	Reliance Electric	500	260	8.0	M R
	10	Patterson	Ideal Electric	900	260	15.0	M R
	11	Patterson	Ideal Electric	900	260	15.0	M R
				2,700		44.5	
SIXTY-FOURTH AVENUE (5,427)	3	Fairbanks Morse	United States	100	90	5.0	M R
(Low Pressure)	6	Fairbanks Morse	United States	200	90	10.0	M R
21850 E. 64th Ave.				300		15.0	
SIXTY-FOURTH AVENUE (5,427)	1	Fairbanks Morse	United States	400	170	10.0	M R
(High Pressure)							
21850 E. 64th Ave.							
			Grand Total	52,875		1,070.6	

Note: City Datum = 5,172.91

[1]M=Manual, R=Remote, L=Local

[2]Vault Type Structure (underground)

[3]Natural Gas Engine